



Note:  
Detector must  
be grounded  
locally.

3x 1mm<sup>2</sup> Shielded  
PE not required

AUX Supply  
24Vdc Max. 2Amp

Note:  
Shield must be  
isolated and  
terminated in  
gland.

230Vac / (24Vdc)

Designed by JA	Checked by LH	Drawing No. EG00123E	Revision C
<b>geopal</b> Bygmarken 19 DK-3520 Farum Phone: +4545670600		Description <b>GJD-L3C</b> <b>230Vac / 24Vdc</b> <b>Incl. GJ-EX d Detector</b>	Date 25-11-2025 Sheet 1/1