



Note:
Detector must
be grounded
locally.

3x 1mm² Shielded
PE not required

AUX Supply
24Vdc Max. 2Amp

Note:
Shield must be
isolated and
terminated in
gland.

230Vac / (24Vdc)

Designed by JA	Checked by	Drawing No. EG00170	Revision B
geopal Bygmarken 19 DK-3520 Farum Phone: +4545670600		Description GJD-02C 230Vac / 24Vdc Incl. GJ-EX d Detector	Date 24-11-2025 Sheet 1/1