



3x 1mm2 Shielded
PE not required
Note: Shield must be
terminated in Cable Gland

AUX Supply
24Vdc Max. 2Amp

DETECTOR No. 2
To be connected as shown
for DETECTOR No. 1

X1: Pin1

230Vac / (24Vdc)

SOUND / BEACON

Only for detector No. 1 shown.
Follow same procedure for detector No. 2

Designed by JA	Checked by LH	Drawing No. EG00185E	Revision A
geopal [®] Bygmarken 19 DK-3520 Farum Phone: +4545670600		Description GJD-04C 230Vac / 24Vdc Incl. GP-SA, GP-ELK Detector and Sound / Beacon	Date 15-01-2026 Sheet 1/1