


Recommended cable size:
Shielded 4-8 x 0,5-1mm² No PE
(Depends on functions used)



Designed by JA	Checked by CM	Drawing No. EG02010E	Revision C
geopal [®] Bygmarken 19 DK-3520 Farum Phone: +4545670600		Description GP-SA / GP-SB, all versions. Quick Guide for installation	Date 05-01-2026
			Sheet 1/1